

# Отчет о теплоснабжении

с 23.09.2021 по 22.10.2021

Потребитель: МП "Горэлектросеть"

Адрес: Железногорск, Улица Саянская, 3 узел № 2

Прибор учета: ВКТ-7 № 258263

| Дата     | Теплоснабжение |        |        |         |         |         |         |        |           | ГВС    |        |        |        |       |        |       |       |            | Нара б., ч |
|----------|----------------|--------|--------|---------|---------|---------|---------|--------|-----------|--------|--------|--------|--------|-------|--------|-------|-------|------------|------------|
|          | T1, °C         | T2, °C | ΔT, °C | V1, м3  | M1, т   | V2, м3  | M2, т   | ΔM, т  | Qот, Гкал | T1, °C | T2, °C | ΔT, °C | V1, м3 | M1, т | V2, м3 | M2, т | ΔM, т | Qгвс, Гкал |            |
| 23.09.21 | 66,3           | 34,7   | 31,6   | 99,91   | 97,93   | 83,06   | 82,58   | 15,35  | 3,550     | ---    | ---    | ---    | ---    | ---   | 15,18  | ---   | ---   | ---        | 24,00      |
| 24.09.21 | 64,9           | 34,3   | 30,6   | 97,97   | 96,07   | 84,11   | 83,63   | 12,44  | 3,301     | ---    | ---    | ---    | ---    | ---   | 15,85  | ---   | ---   | ---        | 24,00      |
| 25.09.21 | 65,2           | 34,3   | 30,9   | 101,55  | 99,58   | 84,99   | 84,50   | 15,08  | 3,512     | ---    | ---    | ---    | ---    | ---   | 15,39  | ---   | ---   | ---        | 24,00      |
| 26.09.21 | 66,0           | 35,9   | 30,1   | 116,06  | 113,81  | 96,20   | 95,63   | 18,18  | 3,982     | ---    | ---    | ---    | ---    | ---   | 17,46  | ---   | ---   | ---        | 24,00      |
| 27.09.21 | 66,5           | 36,1   | 30,3   | 112,71  | 110,45  | 97,44   | 96,84   | 13,61  | 3,766     | ---    | ---    | ---    | ---    | ---   | 18,85  | ---   | ---   | ---        | 24,00      |
| 28.09.21 | 66,4           | 36,0   | 30,4   | 110,85  | 108,65  | 97,35   | 96,74   | 11,91  | 3,663     | ---    | ---    | ---    | ---    | ---   | 19,05  | ---   | ---   | ---        | 24,00      |
| 29.09.21 | 66,3           | 35,8   | 30,5   | 111,10  | 108,90  | 96,48   | 95,96   | 12,94  | 3,717     | ---    | ---    | ---    | ---    | ---   | 18,62  | ---   | ---   | ---        | 24,00      |
| 30.09.21 | 65,6           | 35,9   | 29,7   | 110,32  | 108,17  | 96,26   | 95,72   | 12,45  | 3,595     | ---    | ---    | ---    | ---    | ---   | 18,60  | ---   | ---   | ---        | 24,00      |
| 01.10.21 | 65,6           | 36,0   | 29,6   | 109,05  | 106,94  | 95,09   | 94,51   | 12,43  | 3,545     | ---    | ---    | ---    | ---    | ---   | 18,39  | ---   | ---   | ---        | 24,00      |
| 02.10.21 | 65,6           | 35,3   | 30,2   | 105,57  | 103,50  | 90,15   | 89,67   | 13,83  | 3,543     | ---    | ---    | ---    | ---    | ---   | 16,96  | ---   | ---   | ---        | 24,00      |
| 03.10.21 | 65,9           | 34,9   | 31,0   | 106,12  | 104,01  | 88,72   | 88,24   | 15,77  | 3,690     | ---    | ---    | ---    | ---    | ---   | 16,08  | ---   | ---   | ---        | 24,00      |
| 04.10.21 | 65,5           | 34,6   | 31,0   | 105,97  | 103,89  | 89,08   | 88,60   | 15,29  | 3,663     | ---    | ---    | ---    | ---    | ---   | 16,44  | ---   | ---   | ---        | 24,00      |
| 05.10.21 | 66,5           | 35,1   | 31,4   | 107,85  | 105,70  | 90,77   | 90,28   | 15,42  | 3,777     | ---    | ---    | ---    | ---    | ---   | 16,79  | ---   | ---   | ---        | 24,00      |
| 06.10.21 | 66,7           | 35,3   | 31,4   | 108,87  | 106,69  | 93,14   | 92,66   | 14,03  | 3,773     | ---    | ---    | ---    | ---    | ---   | 17,75  | ---   | ---   | ---        | 24,00      |
| 07.10.21 | 66,5           | 35,7   | 30,8   | 113,29  | 111,05  | 98,64   | 98,03   | 13,02  | 3,814     | ---    | ---    | ---    | ---    | ---   | 19,04  | ---   | ---   | ---        | 24,00      |
| 08.10.21 | 66,5           | 36,5   | 30,0   | 119,08  | 116,71  | 105,34  | 104,62  | 12,09  | 3,874     | ---    | ---    | ---    | ---    | ---   | 20,97  | ---   | ---   | ---        | 24,00      |
| 09.10.21 | 67,5           | 37,4   | 30,1   | 121,95  | 119,44  | 105,69  | 104,97  | 14,47  | 4,051     | ---    | ---    | ---    | ---    | ---   | 20,55  | ---   | ---   | ---        | 24,00      |
| 10.10.21 | 68,2           | 38,2   | 30,0   | 122,52  | 119,95  | 106,56  | 105,84  | 14,11  | 4,059     | ---    | ---    | ---    | ---    | ---   | 20,59  | ---   | ---   | ---        | 24,00      |
| 11.10.21 | 67,9           | 37,9   | 30,0   | 120,41  | 117,91  | 106,08  | 105,35  | 12,56  | 3,951     | ---    | ---    | ---    | ---    | ---   | 21,02  | ---   | ---   | ---        | 24,00      |
| 12.10.21 | 65,7           | 36,3   | 29,4   | 118,42  | 116,10  | 102,83  | 102,15  | 13,95  | 3,847     | ---    | ---    | ---    | ---    | ---   | 19,96  | ---   | ---   | ---        | 24,00      |
| 13.10.21 | 67,2           | 35,6   | 31,6   | 113,58  | 111,27  | 98,47   | 97,92   | 13,35  | 3,919     | ---    | ---    | ---    | ---    | ---   | 17,32  | ---   | ---   | ---        | 24,00      |
| 14.10.21 | 74,7           | 37,8   | 36,9   | 113,98  | 111,17  | 97,21   | 96,49   | 14,68  | 4,578     | ---    | ---    | ---    | ---    | ---   | 14,09  | ---   | ---   | ---        | 24,00      |
| 15.10.21 | 74,6           | 38,0   | 36,7   | 112,17  | 109,38  | 97,87   | 97,15   | 12,23  | 4,412     | ---    | ---    | ---    | ---    | ---   | 14,57  | ---   | ---   | ---        | 24,00      |
| 16.10.21 | 70,6           | 37,1   | 33,4   | 112,68  | 110,16  | 97,60   | 96,90   | 13,26  | 4,109     | ---    | ---    | ---    | ---    | ---   | 14,23  | ---   | ---   | ---        | 24,00      |
| 17.10.21 | 69,3           | 36,8   | 32,5   | 115,07  | 112,58  | 96,82   | 96,15   | 16,43  | 4,173     | ---    | ---    | ---    | ---    | ---   | 13,84  | ---   | ---   | ---        | 24,00      |
| 18.10.21 | 68,7           | 37,1   | 31,6   | 115,58  | 113,15  | 97,56   | 96,87   | 16,28  | 4,090     | ---    | ---    | ---    | ---    | ---   | 14,16  | ---   | ---   | ---        | 24,00      |
| 19.10.21 | 69,2           | 37,5   | 31,7   | 114,23  | 111,78  | 97,65   | 96,95   | 14,83  | 4,025     | ---    | ---    | ---    | ---    | ---   | 14,27  | ---   | ---   | ---        | 24,00      |
| 20.10.21 | 68,1           | 37,2   | 30,9   | 114,28  | 111,90  | 98,13   | 97,45   | 14,45  | 3,919     | ---    | ---    | ---    | ---    | ---   | 14,46  | ---   | ---   | ---        | 24,00      |
| 21.10.21 | 68,6           | 37,9   | 30,7   | 114,35  | 111,92  | 100,00  | 99,28   | 12,64  | 3,845     | ---    | ---    | ---    | ---    | ---   | 14,97  | ---   | ---   | ---        | 24,00      |
| 22.10.21 | 68,0           | 38,4   | 29,6   | 115,59  | 113,20  | 100,82  | 100,10  | 13,10  | 3,787     | ---    | ---    | ---    | ---    | ---   | 14,96  | ---   | ---   | ---        | 24,00      |
| Итого    | ---            | ---    | ---    | 3361,08 | 3291,96 | 2890,11 | 2871,78 | 420,18 | 115,530   | ---    | ---    | ---    | 0,00   | 0,00  | 510,41 | 0,00  | 0,00  | 0,000      | 720,00     |
| Средние  | 67,5           | 36,3   | 31,2   | ---     | ---     | ---     | ---     | ---    | ---       | 0,0    | 0,0    | 0,0    | ---    | ---   | ---    | ---   | ---   | ---        | ---        |

| Дата           | M1, т    | M2, т    | ΔM, т    | Qот, Гкал | V1гвс, м3 | M1 гвс, т | V2гвс, м3 | M2 гвс, т | Qгвс, Гкал | ВНР, ч   |
|----------------|----------|----------|----------|-----------|-----------|-----------|-----------|-----------|------------|----------|
| 23.09.21 00:00 | 75593,56 | 62682,51 | 12911,05 | 3024,249  |           |           | 13285,16  |           |            | 19703,00 |
| 23.10.21 00:00 | 78885,52 | 65554,29 | 13331,23 | 3139,779  |           |           | 13795,57  |           |            | 20423,00 |
| Итого:         | 3291,96  | 2871,78  | 420,18   | 115,530   |           |           | 510,41    |           |            | 720,00   |

Всего по теплоснабжению: Qот = 115,530 Гкал

Всего по ГВС: Qгвс = 0,000 Гкал

Всего по потребителю: Qобщ = 115,530 Гкал

Всего по ГВС: ΔM = 0,00 т

Представитель потребителя Томчук О.В.

Представитель теплоснабжающей организации