

Температура холодной воды (тв): 5,00 °С
Номер активной базы данных: 1
Схема теплоснабжения №3

Тепловой ввод 1

Дата	Qo, Tkan	Qr, Tkan	M1, T	M2, T	Mf, T	V1, m³	V2, m³	dV, m³	BHP, ч	BOC, ч	t1, °C	t2, °C	dt, °C	P1, krc/cm²	P2, krc/cm²	HC DO	HC Or	HC M1	HC M2	HC Mf	HC V1	HC V2	HC t1	HC t2	HC dt	HC P1	HC P2	
26.12.2020	1,232	0,000	22,920	22,920	0,000	24,040	23,690	0,350	24,0	0,0	119,67	66,24	53,43	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
27.12.2020	1,366	-0,004	23,240	23,280	-0,040	24,660	24,100	0,560	24,0	0,0	130,37	70,66	59,71	7,000	5,000	0	0	0	2	0	0	0	0	0	0	0	0	0
28.12.2020	1,492	0,013	23,140	23,040	0,100	24,550	23,800	0,750	24,0	0,0	129,12	69,24	59,88	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
29.12.2020	1,373	0,005	23,160	23,140	0,040	24,520	23,840	0,680	24,0	0,0	127,13	68,34	58,79	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
30.12.2020	1,338	0,001	23,210	23,200	0,010	24,520	23,930	0,590	24,0	0,0	125,41	68,12	57,29	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
31.12.2020	1,084	0,000	22,900	22,900	0,000	23,880	23,660	0,220	24,0	0,0	108,91	61,74	47,17	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
01.01.2021	1,126	0,000	22,560	22,560	0,000	23,550	23,310	0,240	24,0	0,0	111,41	61,73	49,68	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
02.01.2021	1,291	0,000	22,840	22,840	0,000	24,060	23,620	0,440	24,0	0,0	122,55	66,39	56,16	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
03.01.2021	1,202	0,000	23,250	23,250	0,000	24,360	24,060	0,320	24,0	0,0	115,66	64,31	51,35	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
04.01.2021	1,146	0,000	23,150	23,150	0,000	24,140	23,900	0,240	24,0	0,0	111,77	62,43	49,34	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
05.01.2021	1,201	0,000	23,110	23,110	0,000	24,190	23,870	0,320	24,0	0,0	115,72	63,89	51,83	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
06.01.2021	1,074	0,000	23,010	23,010	0,000	23,980	23,800	0,180	24,0	0,0	107,25	60,70	46,55	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
07.01.2021	1,141	0,000	23,260	23,260	0,000	24,250	24,000	0,250	24,0	0,0	110,88	61,99	48,89	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
08.01.2021	1,266	-0,004	23,400	23,440	-0,040	24,600	24,200	0,400	24,0	0,0	120,04	66,20	53,84	7,000	5,000	0	0	0	2	0	0	0	0	0	0	0	0	0
09.01.2021	1,159	-0,004	23,240	23,280	-0,040	24,320	24,020	0,300	24,0	0,0	113,03	63,44	49,59	7,000	5,000	0	0	0	2	0	0	0	0	0	0	0	0	0
10.01.2021	0,958	-0,003	23,050	23,090	-0,040	23,880	23,770	0,110	24,0	0,0	99,81	58,25	41,56	7,000	5,000	0	0	0	2	0	0	0	0	0	0	0	0	0
11.01.2021	0,934	0,015	22,920	22,750	0,170	23,700	23,340	0,360	24,0	0,0	96,54	56,29	40,25	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
12.01.2021	1,126	0,006	22,770	22,710	0,060	23,830	23,410	0,420	24,0	0,0	111,62	62,46	49,16	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
13.01.2021	1,142	0,004	22,630	22,590	0,040	23,710	23,320	0,390	24,0	0,0	113,42	63,32	50,10	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
14.01.2021	1,060	0,005	23,350	23,300	0,050	24,330	24,010	0,320	24,0	0,0	106,53	61,39	45,14	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
15.01.2021	0,987	0,006	23,510	23,450	0,060	24,390	24,130	0,260	24,0	0,0	100,81	59,02	41,79	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
16.01.2021	0,913	-0,009	23,060	23,180	-0,120	23,850	23,820	0,030	24,0	0,0	97,02	57,30	39,72	7,000	5,000	0	0	0	2	0	0	0	0	0	0	0	0	0
17.01.2021	0,783	-0,017	23,030	23,310	-0,280	23,680	23,890	-0,210	24,0	0,0	88,84	54,37	34,47	7,000	5,000	0	0	0	2	0	0	0	0	0	0	0	0	0
18.01.2021	0,666	-0,014	22,480	22,780	-0,300	23,080	23,290	-0,210	24,0	0,0	80,36	50,12	30,24	7,000	5,000	0	0	0	2	0	0	0	0	0	0	0	0	0
19.01.2021	0,784	-0,014	22,460	22,700	-0,240	23,150	23,220	-0,070	24,0	0,0	88,66	53,29	35,37	7,000	5,000	0	0	0	2	0	0	0	0	0	0	0	0	0
20.01.2021	1,024	0,001	22,780	22,780	0,000	23,700	23,440	0,260	24,0	0,0	104,80	60,10	44,70	7,000	5,000	0	0	0	2	0	0	0	0	0	0	0	0	0
21.01.2021	1,146	0,002	22,970	22,950	0,020	24,090	23,660	0,430	24,0	0,0	113,78	64,19	49,59	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
22.01.2021	0,992	0,008	22,860	22,780	0,080	23,780	23,490	0,290	24,0	0,0	102,62	59,62	43,00	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
23.01.2021	0,944	0,000	22,760	22,760	0,000	23,570	23,450	0,120	24,0	0,0	99,87	58,44	41,43	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
24.01.2021	0,959	0,000	22,850	22,850	0,000	23,700	23,570	0,130	24,0	0,0	100,65	59,04	41,61	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
25.01.2021	1,138	0,007	23,030	22,960	0,070	24,100	23,670	0,430	24,0	0,0	112,15	63,16	48,99	7,000	5,000	0	0	0	0	0	0	0	0	0	0	0	0	0
Cpednee	1,096	0,000	22,998	23,011	-0,013	24,006	23,719	0,287	24,0	0,0	109,25	61,80	47,45	7,000	5,000													
Uitro	33,986	0,004	712,930	713,330	-0,400	744,180	735,280	8,900	744,0	0,0	109,25	61,80	47,45	7,000	5,000													
Ha 26.12.20	209,786	1,345	8264,830	8230,230	24,600	8410,440	8446,000	-35,560	12487,0	2,0																		
Ha 25.01.21	243,772	1,349	8967,760	8943,560	24,200	9154,620	9181,280	-26,660	13231,0	2,0																		

Ответственный за учет тепловой энергии:

Отчет принят " " 20 _____

W. 244
A 157



$V_{ГВС} = 2,010 \text{ м}^3$
 $Q_{ГВС} = 0,198 \text{ Гкал.}$

Q_{потреб.}= 34,046 Гкал.
Q_{отопл.}= 33,848 Гкал.

Отчет составлен на основании архивных данных тепловычислителя ВКТ-7-03, зав. №00137277

Температура холодной воды tвх: 5,00 °C
 Номер активной базы данных: 1
 Схема теплоснабжения №6

Суточные данные за период с 26.12.20 по 25.01.21
 Поставщик: г. Железнодорож ул. Комсомольская 43
 Потребитель: УФСБ России по Красноярскому краю

Тепловой ввод 2

Дата	Qo, Гкал	M1, т	V1, м³	dV, м³	ВНР, ч	ВОС, ч	t1, °C	P1, кгс/см²	ис	ис	ис	ис	ис	ис
26.12.2020	0,001	0,010	0,010	24,0	0,0	85,04	5,000	0	0	0	0	0	0	0
27.12.2020	0,000	0,000	0,000	24,0	0,0	43,36	5,000	0	0	0	0	0	0	0
28.12.2020	0,020	0,170	0,180	24,0	0,0	123,27	5,000	0	0	0	0	0	0	0
29.12.2020	0,013	0,110	0,110	24,0	0,0	118,56	5,000	0	0	0	0	0	0	0
30.12.2020	0,007	0,060	0,060	24,0	0,0	115,10	5,000	0	0	0	0	0	0	0
31.12.2020	0,002	0,020	0,020	24,0	0,0	78,28	5,000	0	0	0	0	0	0	0
01.01.2021	0,001	0,010	0,010	24,0	0,0	89,11	5,000	0	0	0	0	0	0	0
02.01.2021	0,001	0,010	0,010	24,0	0,0	88,86	5,000	0	0	0	0	0	0	0
03.01.2021	0,001	0,010	0,010	24,0	0,0	73,30	5,000	0	0	0	0	0	0	0
04.01.2021	0,001	0,010	0,010	24,0	0,0	57,49	5,000	0	0	0	0	0	0	0
05.01.2021	0,000	0,000	0,000	24,0	0,0	48,76	5,000	0	0	0	0	0	0	0
06.01.2021	0,000	0,000	0,000	24,0	0,0	47,24	5,000	0	0	0	0	0	0	0
07.01.2021	0,003	0,030	0,030	24,0	0,0	71,08	5,000	0	0	0	0	0	0	0
08.01.2021	0,003	0,030	0,030	24,0	0,0	96,14	5,000	0	0	0	0	0	0	0
09.01.2021	0,001	0,010	0,010	24,0	0,0	100,62	5,000	0	0	0	0	0	0	0
10.01.2021	0,001	0,010	0,010	24,0	0,0	74,04	5,000	0	0	0	0	0	0	0
11.01.2021	0,023	0,250	0,250	24,0	0,0	92,78	5,000	0	0	0	0	0	0	0
12.01.2021	0,013	0,120	0,120	24,0	0,0	110,45	5,000	0	0	0	0	0	0	0
13.01.2021	0,011	0,110	0,110	24,0	0,0	101,78	5,000	0	0	0	0	0	0	0
14.01.2021	0,012	0,120	0,120	24,0	0,0	102,00	5,000	0	0	0	0	0	0	0
15.01.2021	0,013	0,130	0,130	24,0	0,0	96,41	5,000	0	0	0	0	0	0	0
16.01.2021	0,001	0,010	0,010	24,0	0,0	67,89	5,000	0	0	0	0	0	0	0
17.01.2021	0,001	0,020	0,020	24,0	0,0	61,32	5,000	0	0	0	0	0	0	0
18.01.2021	0,010	0,130	0,130	24,0	0,0	75,46	5,000	0	0	0	0	0	0	0
19.01.2021	0,011	0,140	0,140	24,0	0,0	80,50	5,000	0	0	0	0	0	0	0
20.01.2021	0,008	0,080	0,080	24,0	0,0	99,04	5,000	0	0	0	0	0	0	0
21.01.2021	0,010	0,100	0,100	24,0	0,0	109,92	5,000	0	0	0	0	0	0	0
22.01.2021	0,016	0,160	0,160	24,0	0,0	100,00	5,000	0	0	0	0	0	0	0
23.01.2021	0,001	0,010	0,010	24,0	0,0	68,52	5,000	0	0	0	0	0	0	0
24.01.2021	0,001	0,010	0,010	24,0	0,0	84,66	5,000	0	0	0	0	0	0	0
25.01.2021	0,012	0,120	0,120	24,0	0,0	104,09	5,000	0	0	0	0	0	0	0
Среднее	0,006	0,065	0,065	---	24,0	0,0	86,32	5,000						
Итого	0,198	2,000	2,010	---	744,0	0,0	86,32	5,000						
На 26.12.20	2,809	61,360	61,360	---	12489,0	0,0								
На 25.01.21	3,007	63,360	63,370	---	13233,0	0,0								

Ответственный за учет тепловой энергии:

Отчет принят " " 20 г. /

