

Отчет о теплоснабжении

с 23.02.2022 по 22.03.2022

Потребитель: МП ГЭС

Адрес: Железногорск, Проезд Юбилейный, 4

Прибор учета: ВКТ-7 № 237143

Дата	Теплоснабжение									ГВС									Нара б., ч
	T1, °C	T2, °C	ΔT, °C	V1, м3	M1, т	V2, м3	M2, т	ΔM, т	Qот, Гкал	T1, °C	T2, °C	ΔT, °C	V1, м3	M1, т	V2, м3	M2, т	ΔM, т	Qгвс, Гкал	
23.02.22	76,2	50,6	25,6	176,11	171,32	163,97	162,24	9,08	4,799	---	---	---	59,57	---	52,35	---	---	---	24,00
24.02.22	74,1	48,8	25,2	170,28	165,98	159,50	157,86	8,12	4,541	---	---	---	57,06	---	51,07	---	---	---	24,00
25.02.22	72,9	48,3	24,6	168,88	164,75	159,36	157,70	7,05	4,356	---	---	---	55,98	---	51,22	---	---	---	24,00
26.02.22	74,3	49,0	25,4	172,70	168,20	160,39	158,84	9,36	4,683	---	---	---	58,60	---	51,17	---	---	---	24,00
27.02.22	76,8	50,0	26,9	171,96	167,26	161,04	159,30	7,96	4,854	---	---	---	57,58	---	51,63	---	---	---	24,00
28.02.22	76,4	49,7	26,7	171,88	167,29	161,17	159,42	7,87	4,811	---	---	---	57,50	---	51,73	---	---	---	24,00
01.03.22	78,8	51,8	27,0	178,28	173,28	167,71	165,75	7,53	5,031	---	---	---	59,27	---	53,91	---	---	---	24,00
02.03.22	76,1	50,1	26,1	173,76	169,05	161,95	160,27	8,78	4,799	---	---	---	58,60	---	51,83	---	---	---	24,00
03.03.22	82,1	52,2	29,9	174,21	168,87	163,31	161,41	7,46	5,397	---	---	---	58,12	---	52,46	---	---	---	24,00
04.03.22	79,5	52,3	27,2	178,10	172,95	166,74	164,77	8,18	5,093	---	---	---	59,54	---	53,47	---	---	---	24,00
05.03.22	73,1	48,2	24,9	167,26	163,06	155,95	154,45	8,61	4,438	---	---	---	56,33	---	49,95	---	---	---	24,00
06.03.22	71,8	47,3	24,4	166,87	162,71	155,02	153,67	9,04	4,357	---	---	---	56,45	---	49,54	---	---	---	24,00
07.03.22	71,1	48,3	22,8	174,93	170,65	163,58	162,06	8,59	4,259	---	---	---	58,65	---	52,36	---	---	---	24,00
08.03.22	69,5	47,4	22,2	171,23	167,13	159,49	158,07	9,06	4,087	---	---	---	57,77	---	50,93	---	---	---	24,00
09.03.22	83,4	53,1	30,3	177,20	171,65	166,00	163,96	7,69	5,574	---	---	---	59,08	---	53,15	---	---	---	24,00
10.03.22	97,5	61,1	36,5	191,37	183,00	179,78	177,47	5,53	6,998	---	---	---	62,91	---	57,50	---	---	---	24,00
11.03.22	101,6	63,0	38,5	192,26	183,54	182,03	179,21	4,33	7,341	---	---	---	62,17	---	58,37	---	---	---	24,00
12.03.22	105,6	64,7	40,9	193,09	183,97	181,51	178,36	5,61	7,895	---	---	---	62,69	---	57,76	---	---	---	24,00
13.03.22	107,2	65,4	41,8	192,45	183,31	180,44	177,04	6,27	8,061	---	---	---	62,33	---	56,97	---	---	---	24,00
14.03.22	103,8	63,8	40,0	190,35	181,55	180,20	177,21	4,34	7,544	---	---	---	61,13	---	57,37	---	---	---	24,00
15.03.22	100,6	62,5	38,1	190,32	181,91	179,85	177,01	4,90	7,238	---	---	---	61,60	---	57,40	---	---	---	24,00
16.03.22	98,0	61,4	36,5	190,33	182,42	180,09	177,21	5,21	6,970	---	---	---	61,72	---	57,64	---	---	---	24,00
17.03.22	92,1	58,9	33,2	189,00	181,74	179,19	176,77	4,97	6,308	---	---	---	61,44	---	57,48	---	---	---	24,00
18.03.22	82,7	54,2	28,5	181,84	176,32	171,23	168,96	7,36	5,395	---	---	---	60,19	---	54,91	---	---	---	24,00
19.03.22	79,5	52,1	27,4	180,40	175,14	167,21	165,35	9,79	5,257	---	---	---	61,34	---	53,34	---	---	---	24,00
20.03.22	74,2	48,9	25,3	172,52	168,04	160,49	158,91	9,13	4,652	---	---	---	58,41	---	51,20	---	---	---	24,00
21.03.22	71,5	47,3	24,1	167,85	163,96	156,57	154,92	9,04	4,337	---	---	---	56,59	---	50,03	---	---	---	24,00
22.03.22	70,3	46,6	23,7	165,08	160,99	154,18	152,99	8,00	4,146	---	---	---	55,54	---	49,26	---	---	---	24,00
Итого	---	---	---	4990,51	4830,04	4677,95	4621,18	208,86	153,221	---	---	---	1658,16	0,00	1496,00	0,00	0,00	0,000	672,00
Средние	82,9	53,5	29,4	---	---	---	---	---	---	0,0	0,0	0,0	---	---	---	---	---	---	---

Дата	M1, т	M2, т	ΔM, т	Qот, Гкал	V1гвс, м3	M1 гвс, т	V2гвс, м3	M2 гвс, т	Qгвс, Гкал	ВНР, ч
23.02.22 00:00	60492,46	57603,78	2888,68	1931,159	23735,14		19790,81			11046,00
23.03.22 00:00	65322,50	62224,96	3097,54	2084,380	25393,30		21286,81			11718,00
Итого:	4830,04	4621,18	208,86	153,221	1658,16		1496,00			672,00

Всего по теплоснабжению: Qот = 153,221 Гкал

Всего по ГВС: Qгвс = 0,000 Гкал

Всего по потребителю: Qобщ = 153,221 Гкал

Всего по ГВС: ΔM = 0,00 т

Представитель потребителя Томчук О.В.

Представитель теплоснабжающей организации _____