

Отчет о теплоснабжении

с 23.04.2021 по 22.05.2021

Потребитель: ООО ЖКУ

Адрес: 60 лет ВЛКСМ 22

Прибор учета: ВКТ-7 № 245818

Дата	Теплоснабжение									ГВС									Нара б., ч
	T1, °C	T2, °C	ΔT, °C	V1, м3	M1, т	V2, м3	M2, т	ΔM, т	Qот, Гкал	T1, °C	T2, °C	ΔT, °C	V1, м3	M1, т	V2, м3	M2, т	ΔM, т	Qгвс, Гкал	
23.04.21	69,3	44,1	25,2	89,35	87,46	81,78	81,03	6,43	2,452	---	---	---	7,73	---	10,31	---	---	---	24,00
24.04.21	69,9	44,8	25,0	90,02	88,06	82,94	82,18	5,88	2,439	---	---	---	7,25	---	10,58	---	---	---	24,00
25.04.21	69,1	44,3	24,8	89,37	87,49	81,77	81,02	6,47	2,424	---	---	---	7,74	---	11,48	---	---	---	24,00
26.04.21	69,7	45,1	24,6	91,77	89,83	83,40	82,64	7,19	2,498	---	---	---	8,52	---	12,86	---	---	---	24,00
27.04.21	69,8	45,0	24,8	87,20	85,31	80,04	79,26	6,05	2,355	---	---	---	7,15	---	10,20	---	---	---	24,00
28.04.21	67,6	43,7	23,9	84,21	82,48	77,44	76,68	5,80	2,192	---	---	---	6,72	---	11,04	---	---	---	24,00
29.04.21	68,1	44,2	24,0	86,14	84,34	78,65	77,88	6,46	2,273	---	---	---	7,47	---	10,13	---	---	---	24,00
30.04.21	68,2	44,6	23,6	87,46	85,63	79,75	79,03	6,60	2,282	---	---	---	7,67	---	11,30	---	---	---	24,00
01.05.21	68,6	45,0	23,5	88,31	86,44	80,49	79,75	6,69	2,300	---	---	---	7,76	---	12,23	---	---	---	24,00
02.05.21	68,0	44,5	23,5	86,48	84,69	80,22	79,49	5,20	2,195	---	---	---	6,12	---	9,53	---	---	---	24,00
03.05.21	67,9	44,5	23,3	87,13	85,31	80,17	79,44	5,87	2,220	---	---	---	6,83	---	9,76	---	---	---	24,00
04.05.21	68,1	44,7	23,4	87,22	85,40	80,73	80,00	5,40	2,213	---	---	---	6,31	---	8,84	---	---	---	24,00
05.05.21	67,6	44,1	23,5	86,76	84,96	79,69	78,96	6,00	2,228	---	---	---	6,88	---	8,78	---	---	---	24,00
06.05.21	68,6	45,5	23,2	87,80	85,96	81,06	80,30	5,66	2,217	---	---	---	6,47	---	9,32	---	---	---	24,00
07.05.21	68,9	46,0	23,0	88,32	86,44	81,99	81,21	5,23	2,197	---	---	---	6,03	---	9,73	---	---	---	24,00
08.05.21	68,6	45,8	22,8	88,45	86,58	81,51	80,75	5,83	2,211	---	---	---	6,70	---	10,74	---	---	---	24,00
09.05.21	68,4	45,2	23,2	87,60	85,80	80,59	79,86	5,94	2,229	---	---	---	6,72	---	10,49	---	---	---	24,00
10.05.21	68,7	45,7	23,0	88,93	87,06	80,95	80,21	6,85	2,279	---	---	---	7,71	---	12,15	---	---	---	24,00
11.05.21	68,9	46,8	22,1	92,71	90,72	85,38	84,48	6,24	2,270	---	---	---	7,05	---	12,16	---	---	---	24,00
12.05.21	69,3	48,0	21,3	97,41	95,32	90,22	89,18	6,14	2,294	---	---	---	7,05	---	11,15	---	---	---	24,00
13.05.21	69,4	47,7	21,8	93,18	91,17	86,39	85,42	5,75	2,233	---	---	---	6,52	---	9,01	---	---	---	24,00
14.05.21	68,0	46,5	21,5	91,74	89,85	84,13	83,27	6,58	2,206	---	---	---	7,35	---	11,38	---	---	---	24,00
15.05.21	67,3	45,5	21,9	89,93	88,08	82,28	81,54	6,54	2,186	---	---	---	7,32	---	10,98	---	---	---	24,00
16.05.21	68,3	46,2	22,1	92,53	90,59	83,78	82,88	7,71	2,319	---	---	---	8,53	---	12,20	---	---	---	24,00
17.05.21	68,9	46,5	22,4	91,64	89,71	84,47	83,55	6,16	2,266	---	---	---	6,83	---	9,16	---	---	---	24,00
18.05.21	69,3	46,3	23,0	89,25	87,32	82,85	82,01	5,31	2,225	---	---	---	5,94	---	8,95	---	---	---	24,00
19.05.21	70,3	46,6	23,7	88,87	86,93	81,61	80,79	6,14	2,316	---	---	---	6,81	---	9,94	---	---	---	24,00
20.05.21	71,2	46,7	24,5	87,08	85,13	79,76	79,02	6,11	2,342	---	---	---	6,76	---	10,64	---	---	---	24,00
21.05.21	70,9	46,3	24,6	87,37	85,41	79,47	78,73	6,68	2,373	---	---	---	7,38	---	10,63	---	---	---	24,00
22.05.21	69,7	46,0	23,7	86,24	84,34	79,72	78,98	5,36	2,222	---	---	---	5,97	---	10,62	---	---	---	24,00
Итого	---	---	---	2670,47	2613,81	2453,23	2429,54	184,27	68,456	---	---	---	211,29	0,00	316,29	0,00	0,00	0,000	720,00
Средние	68,9	45,5	23,4	---	---	---	---	---	---	0,0	0,0	0,0	---	---	---	---	---	---	---

Дата	M1, т	M2, т	ΔM, т	Qот, Гкал	V1гвс, м3	M1 гвс, т	V2гвс, м3	M2 гвс, т	Qгвс, Гкал	ВНР, ч
23.04.21 00:00	2483,95	2303,58	180,37	69,901	224,17	---	---	---	---	682,00
23.05.21 00:00	5097,76	4733,12	364,64	138,357	435,46	---	639,36	---	---	1402,00
Итого:	2613,81	2429,54	184,27	68,456	211,29	---	639,36	---	---	720,00

Всего по теплоснабжению: Qот = 68,456 Гкал

Всего по ГВС: Qгвс = 0,000 Гкал

Всего по потребителю: Qобщ = 68,456 Гкал

Всего по ГВС: ΔM = 0,00 т

Представитель потребителя Томчук О.В.

Представитель теплоснабжающей организации _____