

# Отчет о теплоснабжении

с 23.09.2021 по 22.10.2021

Потребитель: Жилой многоквартирный дом

Адрес: г. Железнодорожск, ул. Королева, 9

Договор №: \_\_\_\_\_ от \_\_\_\_\_

Абонент №: \_\_\_\_\_

Прибор учета: ВКТ-7 № 234943

| Дата     | Теплоснабжение |        |        |         |         |        |         |         |        |           |         |         | Нараб., ч |
|----------|----------------|--------|--------|---------|---------|--------|---------|---------|--------|-----------|---------|---------|-----------|
|          | T1, °C         | T2, °C | ΔT, °C | V1, м3  | V2, м3  | ΔV, м3 | M1, т   | M2, т   | ΔM, т  | Qот, Гкал | P1, атм | P2, атм |           |
| 23.09.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 24.09.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 25.09.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 26.09.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 27.09.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 28.09.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 29.09.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 30.09.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 01.10.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 02.10.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 03.10.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 04.10.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 05.10.21 | ---            | ---    | ---    | ---     | ---     | ---    |         |         |        | ---       | ---     | ---     | ---       |
| 06.10.21 | 67,6           | 37,8   | 29,9   | 42,06   | 36,44   | 5,62   | 41,19   | 36,20   | 4,99   | 1,392     | 4,38    | 4,20    | 12,00     |
| 07.10.21 | 66,9           | 36,9   | 30,0   | 79,83   | 70,50   | 9,33   | 78,37   | 69,86   | 8,51   | 2,617     | 3,96    | 3,90    | 24,00     |
| 08.10.21 | 66,9           | 37,0   | 30,0   | 80,24   | 71,41   | 8,83   | 78,69   | 70,82   | 7,87   | 2,603     | 3,96    | 3,89    | 24,00     |
| 09.10.21 | 67,9           | 38,2   | 29,8   | 83,60   | 74,75   | 8,85   | 81,98   | 74,13   | 7,85   | 2,699     | 3,91    | 3,83    | 24,00     |
| 10.10.21 | 68,7           | 38,9   | 29,8   | 85,52   | 75,44   | 10,08  | 83,81   | 74,75   | 9,06   | 2,801     | 3,90    | 3,82    | 24,00     |
| 11.10.21 | 68,3           | 38,2   | 30,1   | 82,38   | 72,74   | 9,64   | 80,74   | 72,15   | 8,59   | 2,714     | 3,84    | 3,77    | 24,00     |
| 12.10.21 | 66,0           | 35,5   | 30,5   | 75,44   | 64,59   | 10,85  | 73,96   | 64,19   | 9,77   | 2,551     | 3,86    | 3,82    | 24,00     |
| 13.10.21 | 68,1           | 36,1   | 32,0   | 79,29   | 68,08   | 11,21  | 77,70   | 67,57   | 10,13  | 2,800     | 3,89    | 3,83    | 24,00     |
| 14.10.21 | 75,5           | 41,1   | 34,4   | 90,54   | 82,96   | 7,58   | 88,44   | 82,07   | 6,37   | 3,267     | 4,03    | 3,92    | 24,00     |
| 15.10.21 | 75,2           | 41,4   | 33,9   | 89,76   | 82,99   | 6,77   | 87,59   | 82,20   | 5,39   | 3,159     | 4,02    | 3,91    | 24,00     |
| 16.10.21 | 71,0           | 40,1   | 30,9   | 89,70   | 81,66   | 8,04   | 87,89   | 80,77   | 7,12   | 2,964     | 4,09    | 3,98    | 24,00     |
| 17.10.21 | 69,9           | 39,6   | 30,3   | 91,35   | 80,51   | 10,84  | 89,40   | 79,81   | 9,59   | 3,034     | 4,06    | 3,95    | 24,00     |
| 18.10.21 | 69,5           | 39,8   | 29,7   | 92,65   | 80,71   | 11,94  | 90,64   | 80,11   | 10,53  | 3,052     | 4,05    | 3,94    | 24,00     |
| 19.10.21 | 70,0           | 40,3   | 29,8   | 91,89   | 82,38   | 9,51   | 89,89   | 81,69   | 8,20   | 2,962     | 4,10    | 3,99    | 24,00     |
| 20.10.21 | 68,9           | 40,4   | 28,5   | 92,69   | 84,80   | 7,89   | 90,85   | 83,96   | 6,89   | 2,828     | 4,08    | 3,96    | 24,00     |
| 21.10.21 | 69,4           | 41,2   | 28,2   | 95,53   | 87,48   | 8,05   | 93,46   | 86,79   | 6,67   | 2,872     | 4,07    | 3,94    | 24,00     |
| 22.10.21 | 68,7           | 42,3   | 26,4   | 98,20   | 91,43   | 6,77   | 96,29   | 90,46   | 5,83   | 2,758     | 4,09    | 3,94    | 24,00     |
| Итого    | ---            | ---    | ---    | 1440,67 | 1288,87 | 151,80 | 1410,89 | 1277,53 | 133,36 | 47,073    | ---     | ---     | 396,00    |
| Средние  | 39,3           | 22,2   | 17,1   | ---     | ---     | ---    | ---     | ---     | ---    | ---       | 2,28    | 2,22    | ---       |

| Дата              | V1, м3  | V2, м3  | ΔV, м3 | M1, т   | M2, т   | ΔM, т  | Qот, Гкал | ВНР, ч |
|-------------------|---------|---------|--------|---------|---------|--------|-----------|--------|
| 23.09.21 00:00:00 |         |         |        | ---     | ---     | ---    |           |        |
| 23.10.21 00:00:00 | 1440,67 | 1288,87 | 151,80 | 1410,89 | 1277,53 | 133,36 | 47,073    | 396,00 |
| Итого:            | 1440,67 | 1288,87 |        | 1410,89 | 1277,53 | 133,36 | 47,073    | 396,00 |

Всего по теплоснабжению: Qот = 47,073 Гкал

Представитель потребителя Директор ООО "Комфортное жилье" Шалагина Н.В.,

Представитель теплоснабжающей организации \_\_\_\_\_